



FM Approvals  
1151 Boston-Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

**RSabLEDc. LED Gage Glass Luminator.**  
IS / I, II / 1 / ABCDEFG / T4 Ta = 60°C – R5400.  
a = Options I or H.  
b = Number of Window Units, 5 through 10.  
c = Options EX or blank.

*Special Conditions of Use:*

1. *Must only be used with the FM Approved Pab1c Phaeton Series Tank Light Power Supply.*

### Equipment Ratings:

Intrinsically Safe for use in Class I, II, Division 1, Groups A, B, C, D, E, F, and G, Temperature Class T4  
Ta = 60°C Hazardous (Classified) Locations in accordance with control drawing number J500.32.

### Approved for:

The Clark Reliance Corporation  
Strongsville, OH 44136



This certifies that the equipment described has been found to comply with the following FM Approval Standards and other documents:

Class 3600	1998
Class 3610	1999
Class 3810	1989
Supplement 1	1995


Original Project ID: 3020077

FM Approval Granted: *August 16, 2004*

Subsequent Revision Reports / Date FM Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Global Technologies LLC

  
\_\_\_\_\_  
Robert L. Martell, Jr.  
Assistant Vice President

*August 16, 2004*  
\_\_\_\_\_  
Date