

Northbrook, Illinois • (847) 272-8800
Melville, New York • (631) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500



Underwriters Laboratories Inc.®

CLARK-RELIANCE CORP
MR M COLMAN
16633 FOLTZ INDUSTRIAL PKWY
STRONGVILLE OH 44136

RE: Project Number(s) - 00NK27911

Your most recent listing is shown below. Please review this information and report any inaccuracies to the UL Engineering staff member who handled your project.

For information on placing an order for UL Listing Cards in a 3 x 5 inch format, please refer to the enclosed ordering information.

NOIV November 2, 2000
Auxiliary Devices for Use in Hazardous Locations

CLARK-RELIANCE CORP
16633 FOLTZ INDUSTRIAL PKWY, STRONGVILLE OH 44136

E134983

Class I, Groups A, B, C and D.
Class I, Groups B, C and D; Class II, Groups E, F and G.
Class I, Groups C and D.

Magnetically operated float switch.
Class I, Groups A, B, C and D.
Model SAS-16, Part No. A-25669.
Magnetically operated reed switches.
Class I, Groups B, C and D; Class II, Groups E, F and G.
Model RS-2, Part Nos. A24305, A24751 followed by 1 or 2, followed by LH or RH.
Magnetically operated limited switch.
Class I, Groups C and D.
Type DCEP, Model A-23912.

LOOK FOR LISTING MARK ON PRODUCT

DESCRIPTION

PRODUCT COVERED:

USL, CNL Industrial Control Equipment, Float Operated,
Motor Controllers. For use in
Class I, Division 1, Groups A, B, C, and D
Hazardous Locations. Model SAS-16

GENERAL:

This product is a float operated magnetic level switch, intended to be mounted on a vertical pipe.

ELECTRICAL RATINGS:

These devices use an "X4" switch mechanism with the following ratings:

Maximum switching voltage alternating current - 300 V ac
Maximum switching current alternating current - 10 A ac
Maximum switching power alternating current - 2000 VA ac

Maximum switching voltage direct current - 240 V dc
Maximum switching current direct current - 10 A dc
Maximum switching power direct current - 50 W dc

ENGINEERING CONSIDERATIONS (NOT FOR FIELD REPRESENTATIVE'S USE):

CNL indicates investigation to Canadian Standard C22.2 No. 14-95.

USL indicates investigation to United States Standards UL 508 and UL 698.