



STANDARD SIZES

PART NO.	A	B	C	D	E	F	MIN. S5777 V.G. CENTERS ('A' DIM)
SINGLE WINDOW GAGES							
FG2004	10.625	6.625					15
FG2005	11.750	7.750					16
FG2006	13.000	9.000					17
FG2007	14.125	10.125					19
DOUBLE WINDOW GAGES							
FG2055	16.000	12.000			3.500		20
FG2066	19.000	15.000			3.000		23
FG2077	21.000	17.000			3.250		25

NOTE: 2" MINIMUM FOR DIMENSIONS 'D' AND 'E'

LIST OF MATERIAL PER WINDOW

ITEM	PART NO.	REQ.	DESCRIPTION	MATERIAL	DWG. NO.
1	FG**1	1	BODY	STEEL	
2	X173800		STUD 1/2"-20	A-193-B7	
3	FG1500	2	CLAMP	STEEL	A-8585
4	X171510		HEX NUT 1/2"-20	A-194-2H	
5	X174225		WASHER	STEEL	
6	V15841	2	ALUMINOSILICATE GLASS	GLASS	V-15841
7	RWG89	60	SEALING GASKET	GRAF-DIL	B-11060
8	V17352	2	CUSHION GASKET	GASKET	V-17352
9	FG621	3	MICA	MICA	B-7701
10	PG**2	2	COVER PLATE	STEEL	A-3749U
11	E10	9	HEX PLUG 5/8-18	STEEL	A-6805-5
12	X175500		PLUG GASKET	MONEL	A-541B
13	FG40	8	NAME PLATE	ALUMINUM	A-3876-1
14	PW-33	2	ADAPTOR	304SS	B-14312
15	PW-30	2	PLUG	303SS	B-14312
16	PW-28	2	CONNECTOR	304SS	B-14312
17	RSG477-2	2	FLANGE 1/2"-#2500		A-5819

TO COMPLETE PART NO. * ADD LAST NUMERAL OF INSERT NO.
** ADD INSERT NO.

WORKING STEAM PRESSURE: 2000 PSI
HYDROSTATIC TEST PRESSURE 3000 PSI * TOLERANCES DEFINED BY PES-004

MATERIAL: SEE PES-009

DRAWN: BAC CHECKED:

SCALE: NONE DATE: 4/24/96

REV 1 PER CDC 96-098
2) CDC04-131 REMOVED SIDE CLEAN OUT CONN. 10/26/04 ST

CLARK-RELIANCE CORP.
STRONGVILLE, OHIO, U.S.A.

PART NO.: SEE TABLE

FG2000 MICA-PROTECTED
FLAT GLASS GAGES

TOLERANCE CLASS: B

DRAWING
NUMBER:

FG1179-A

REV.

2